

CODE WORD

This procedure is used to clarify provisions of the Harris County Fire Code. It's sole intent is to clarify what is acceptable practice.

Issue Date: March 1, 2007

Subject: *Fire Code Review for Water Treatment Plants*

Question: Are water treatment plants required to have a Fire Code Review?

Answer: Fire Code review for water treatment plants will be limited to buildings which are occupied on a full or part time basis, such as control rooms. Structures such as equipment housings, pump shelters and chemical buildings located within a normally locked, fenced enclosure will not be reviewed and will not require inspection.



Building Official
Harris County, Texas



Fire Marshal
Harris County, Texas